

敬啟者：

驗鉛水報告合格

本校於8月尾已自行將學校食水交予生產力促進局進行驗水。至2015年9月3日收到驗鉛水報告，沒有超標，師生可放心享用食水。

HKPC Hong Kong Productivity Council 香港生產力促進局

Environment and Product Innovation Laboratory

TEST REPORT

Test Report No : T0060561
Folder No : 1508929
Page No : Page 1 of 1
Date of Issue : 02/09/2015

Client : 筲箕灣街坊福利會張錦添紀念幼稚園
Address : 筲箕灣南安街103號2樓

Sample Description : 2 Drinking water samples were delivered by the client.
Sample Received Date : 26/08/2015 Test Completed Date : 01/09/2015
Remarks : Contact person : 龔副校長. Receipt No:K1158820.


Analytical Results:

Sample Name	Sample No	Parameter Unit Method Code Analysis Date	Lead ug/L WTM-ICPMS-1 27/08/2015
1) 廚房水龍頭	WT-1508-3031		<1
2) 煲水專用水龍頭	WT-1508-3032		<1

-- End of Report --

TESTING METHODS

Parameter	Method	Reference
ICP-MS Full Quantitation (Water & Waste Water)	WTM-ICPMS-1	In-house, ICP/MS

Approval Signatory:

Fung Kam Wing (Consultant)

Notes: (1) This report may not be reproduced except with prior written approval from the issuing laboratory.
(2) Testing Conditions are shown at the back of this report.
(3) N.R. refers to test not required by the Client Company.

HKPC Building, 78 Tat Chee Avenue, Kowloon, Hong Kong • 香港九龍德輔道中78號生產力大樓
Tel 電話 : [852] 2788 5678 • Fax 傳真 : [852] 2788 5900 • Website 網址 : <http://www.hkpc.org>

此致

貴家長

筲箕灣街坊福利會
張錦添紀念幼稚園暨幼兒園
22-9-2015